



2013-01 - LEON VALLEY PUBLIC LIBRARY CHILDREN'S WING

ADDENDUM #1

1. Is the fascia, soffit & closer panel to be 12ga galvanized as per 5/A-4.1 or aluminum per 1&4/A5.1?
 - All Fascia, Soffit, Gutters and Closures are to be 24 Ga. Galvalume metal material.
2. There are no utility drawings, please advise.
 - Questions regarding utilities beyond scope of MEP Drawings may be directed to Byron Vick, Public Works Director at (210) 681-1232.
3. The following specifications are not found: hollow metal, resilient floor, damp-proofing, signage, paper towel dispenser/disposal.
 - The paper towel dispenser/disposal will be reused from existing. We will provide specifications for the hollow metal frames, resilient flooring, and damp-proofing. The signage should be built as detailed.
4. Confirm this projects tax status, is it tax exempt?
 - The City of Leon Valley is tax exempt, however, the City does not provide tax exemption certificates to vendors. Tax Exemption Certificates are available online at <http://www.cpa.state.tx.us/taxinfo/taxforms/01-3392.pdf>.
5. There is a reference to Alt 2 on the exterior concrete slab outside the building foot print. There is not an Alt 2 indicated in the bid documents. Please advise.
 - Please disregard any reference to alt work in structural drawings as all alternates have been removed from scope of work.

Vendors are required to acknowledge this Addendum #1 on the PROPOSAL FORM page PF-1.


Rhonda Hewitt
Purchasing Agent